

Software Name: ioLogik W5340-HSPA Firmware

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
1.3	Build14012218	N/A	ioLogik W5340-HSPA	<p>New Features: Newly release</p> <p>Enhancements: N/A</p>	<p>Bugs Fixed: N/A</p> <p>Changes: N/A</p>	N/A
1.4	Build14050917	N/A	ioLogik W5340-HSPA	<p>New Features: N/A</p> <p>Enhancements: Support SMTP port number change.</p>	<p>Bugs Fixed: N/A</p> <p>Changes: N/A</p>	For Supporting SMTP port number changing, please update the utility to ioAdmin v3.17.
1.5	Build16012018	N/A	ioLogik W5340-HSPA	<p>New Features: N/A</p> <p>Enhancements: Removed cellular multiple band options to prevent from connection failure (compatible with ioAdmin v3.18 only)</p>	<p>Bugs Fixed:</p> <ol style="list-style-type: none"> Fixed unable to set the value of virtual channel from -0.1 to -0.9 Fixed Click&Go cannot compare positive value of virtual channel Fixed FIR in the C&G IF condition did not link to working value but initial value only Fixed SMS escalation only send once when system starts-up Fixed the relay never stop issue when setup ON Width = 1, OFF Width = 22, and Output = 3 pulses Fixed when Click&Go IF condition set to ioLogik E1242 DI=ON, then ioLogik E1242 DO=ON, else ioLogik E1242 DO=OFF, once the ioLogik E1242 DI is triggered, Device status on AOPC server will show offline and quickly then online again 	N/A

Software Name: ioLogik W5340-HSPA Firmware

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
1.6	Build16101715	N/A	ioLogik W5340-HSPA	New Features: 1. Added alive check for 9500 port to MX-AOPC UA Server Enhancements: 1. Increased password length from 8 to 16	Bugs Fixed: N/A Changes: N/A	N/A